



CERTIFIED MATERIAL TEST REPORT

US-ML-MIDLOTHIAN
300 WARD ROAD
MIDLOTHIAN, TX 76065
USA

CUSTOMER SHIP TO SOPORTE LOGISTICO EN DISTRIBUCION 02 715 KMB 1023 507 ZVP MONTERREY,NL 64290 Mexico		CUSTOMER BILL TO GERDAU CORSA S A P I DE CV CARRETERA MEXICO CD SAHAGUN SN CD SAHAGUN,HGO 43990 Mexico		GRADE 992/572-50	SHAPE / SIZE Wide Flange Beam / 14 X 61# / 360 X 91	
SALES ORDER 348626/000020		CUSTOMER MATERIAL N°		LENGTH 40'00"	WEIGHT 61,000 LB	HEAT / BATCH 59054293/03
CUSTOMER PURCHASE ORDER NUMBER 4500674674				BILL OF LADING 1327-0000056489		DATE 23.05.2013
SPECIFICATION / DATE or REVISION A572/A572M-07 A992/A992M-11 ASTM A6/A6M-11						

CHEMICAL COMPOSITION													
C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Nb	Al	
%	%	%	%	%	%	%	%	%	%	%	%	%	%
0.06	0.81	0.011	0.038	0.22	0.36	0.10	0.15	0.027	0.010	0.002	0.019	0.002	


CHEMICAL COMPOSITION	
CEqvA6	%
0.3	


MECHANICAL PROPERTIES							
YS	UTS	YS	UTS	G/L	G/L		
KSI	KSI	MPa	MPa	inch	mm		
50.6	67.6	362	473	8.000	200.0		
52.5	68.6	349	466	8.000	200.0		

MECHANICAL PROPERTIES		
Elong	Y/T rati	
%	%	
26.00	0.765	
27.80	0.749	

COMMENTS / NOTES

The above figures are certified chemical and physical test records as contained in the permanent records of company. This material, including the billets, was melted and manufactured in the USA. We certify that these data are correct and in compliance with specified requirements. CMTR complies with EN 10204 3.1.


 BHASKAR YALAMANCHILI
 QUALITY DIRECTOR


 TOM HARRINGTON
 QUALITY ASSURANCE MGR.