

GERDAU CORSA SAPI DE CV
 KM. 3 CARRETERA MEXICO - SAHAG
 GERDAU CORSA SAPI DE CV, MEXICO
 43990
 SAHAGÚN

CLIENTE A ENVIAR
 ACEROS TEPOTZOTLAN SA DE CV
 CARRETERA MEXICO ORO KM 37.5
 CUAUTITLAN IZCALLMEX 54730
 México

CLIENTE A FACTURAR
 ACEROS TEPOTZOTLAN SA DE CV
 CARRETERA MEXICO ORO KM 37.5
 CUAUTITLAN IZCALLMEX 54730
 México

GRADO
 ASTM A992/A572 G50

LONGITUD
 12.20 M

PRODUCTO / MEDIDA
 Wide Flange Beam / 12 x 35# / 310 x 52.1

PESO
 3,814 KG

ESPECIFICACION TÉCNICA
 ASTM A572-13 G50
 ASTM A6-14
 ASTM A992-11 (2015)
 CSA G40.21-13 345W/M

COLADA / LOTE
 1102243904

CERTIFICATE ID
 0000107211

ORDEN DE COMPRA DEL CLIENTE 002-002790-1	CARTA DE EMBARQUE	FECHA 06.07.2020
PEDIDO DE VENTA 9054599/000040		CUSTOMER MATERIAL N°

COMPOSICION QUIMICA	C	Mn	S	P	Cr	Cu	Mo	Nb	Ni	Si	V	C.E.	Pb
%	%	%	%	%	%	%	%	%	%	%	%	%	%
0.178	0.900	0.038	0.012	0.095	0.276	0.019	0.015	0.081	0.183	0.001	0.374	0.000	

COMPOSICION QUIMICA	Sp
%	%
0.016	

PROPIEDADES MECANICAS	YS/FY	UTS/FU	Elong	YS/FY	G/L
MPa	MPa	%	MPa	mm	
63.4	66.5	18.5	458.2	200	
	78.0	23.4	537.5	200	

PROPIEDADES MECANICAS	YS/UTS
0.85	
0.81	

COMENTARIOS / NOTAS

1P120203540

ISMAEL LÓPEZ ESTRADA
 GERENTE DE CALIDAD MÉXICO

00126549