

GERDAU CORSA SAPI DE CV
 KM. 3 CARRETERA MÉXICO - SAHAG
 GERDAU CORSA SAPI DE CV, MEXICO
 43990
 SAHAGÚN

CLIENTE A ENVIAR ACEROS TEPOTZOTLAN SA DE CV CARRETERA MEXICO QRO KM 37 5 CUAUTITLAN IZCALLI.MEX 54730 México	CLIENTE A FACTURAR ACEROS TEPOTZOTLAN SA DE CV CARRETERA MEXICO QRO KM 37 5 CUAUTITLAN IZCALLI.MEX 54730 México	GRADO ASTM A992/A572 G50	PRODUCTO / MEDIDA Wide Flange Beam / 14 x 34# / 360 x 50.6	CERTIFICATE ID 0000096882
PEDIDO DE VENTA 8673994/000040		CUSTOMER MATERIAL N°	ESPECIFICACIÓN TÉCNICA ASTM A572-13 G50 ASTM A6-14 ASTM A992-11 (2015) CSA G40.21-13 345WM	
ORDEN DE COMPRA DEL CLIENTE 002-002550-1	CARTA DE EMBARQUE	FECHA 26.02.2020	LONGITUD 12.20 M	PESO 25.928 KG
			COLADA / LOTE 11020665/03	


COMPOSICIÓN QUÍMICA												
C %	Mn %	S %	P %	Cr %	Cu %	Mo %	Nb %	Ni %	Si %	V %	C.E.	Pb %
0.192	0.833	0.033	0.014	0.124	0.289	0.015	0.016	0.080	0.214	0.000	0.383	0.002

COMPOSICIÓN QUÍMICA
Sn %
0.023

PROPIEDADES MECÁNICAS					
YS/FY KSI	UTS/FU KSI	Elong. %	UTS/FU MPa	YS/FY MPa	G/L mm
60.4	80.7	30.0	556.1	416.4	200

PROPIEDADES MECÁNICAS
YS/UTS
0.75

COMENTARIOS / NOTAS



CARLOS MOSS VELEZ

00115744

1P140703440