

QUALITY RESULT
 Chemical and Physical Test Report

MILL:
 CALLE 3 S/N, COL. INDEPENDENCIA TUTLTITLAN, EDO. DE MEXICO
 CP. 54 900 TEL. FAX. 5894-08-99


Date June 19, 2018

Customer: PLESA ANAHUAC Y CIAS SA DE CV

Ref.	Heat	Grade	Product	Dimension		Lenght m	C %	Mn %	Si %	S %	P %	Cr %	Ni %	Cu %	Yield Point		Tensile Resistance		Elongation %
				in	mm										MPa	kgf/mm2	MPa	kgf/mm2	
8112323120	9901091902	A36	ROUND	1/2"	12.70	6.10	0.16	0.83	0.15	0.038	0.011	0.08	0.13	0.28	416	42.37	549	55.94	20.50
8112323120	9901092002	A36	ROUND	1/2"	12.70	6.10	0.19	0.76	0.23	0.043	0.008	0.06	0.10	0.31	357	36.39	504	51.42	23.00

Test in accordance with the standares:

- | | |
|--|--|
| <input type="checkbox"/> NMX-B-113-1981 | <input type="checkbox"/> NMX-B-252-1988 |
| <input checked="" type="checkbox"/> NMX-B-172-1988 | <input type="checkbox"/> NMX-B-254-1987 |
| <input checked="" type="checkbox"/> ASTM A 370 05 | <input checked="" type="checkbox"/> ASTM A 6/A 6M 07 |
| <input checked="" type="checkbox"/> ASTM E 415 99a | <input checked="" type="checkbox"/> ASTM A 36/A 36M 05 |
| | <input type="checkbox"/> ASTM A 529/A 529M 05 |
| | <input type="checkbox"/> ASTM A 572M 05 |
| | <input type="checkbox"/> ASTM A 615/A 615M 06a |

QUALITY RESPONSABLE	
Name	<u>Norma Asunción Vitales García</u>
Occupation	<u>Head of Quality Assurance</u>
Signature	

Forbidden the total or partial reproduction gives this report, with out previous authorization of GERDAU CORSA PLANTA TULTITLAN