

11May09 9:13

TEST CERTIFICATE

No: DCR 587339

Sold By: INDEPENDENCE TUBE CORPORATION 6226 W. 74TH STREET CHICAGO, IL 60638 Tel: 708-496-0380 Fax: 708-563-1950

P/O No CB01309 Rel S/O No DCR 12543-002 B/L No DCR 9986-001 Inv No

E. RUIZ Shp 04May09 Inv

Sold To: (2950) MIRACERO S.A. de C.V. CALLE de la FUENTE 403 PISO 2 INT A COL MONCLOVA CENTRO MONCLOVA, COAHUILA, MX 54030 MEXICO

Ship To: (1) MIRACERO S.A. de C.V. VIA 826 PUERTA 94 ZONA 11 NO. de CLIENTE 9092 TLALNEPANTLA, ESTADO deMX MEXICO

Tel:

CERTIFICATE of ANALYSIS and TESTS

Cert. No: DCR 587339 04May09

Part No TUBING A500 GRADE B(C) 12" SQ X 1/4" X 40' Pcs 66 Wgt 104,097

Table with columns: Heat Number, Tag No, YLD/TEN/ELG, Pcs, Wgt. Lists various heat numbers and their corresponding weights and specifications.

Heat Number 7431H X64715 *** Chemical Analysis *** C=0.1900 Mn=0.8400 P=0.0070 S=0.0260 Si=0.0200 Al=0.0300 Cu=0.0200 C=0.2000 Mn=0.7700 P=0.0080 S=0.0150 Si=0.0100 Al=0.0430 Cu=0.0500

WE PROUDLY MANUFACTURE ALL OF OUR HSS IN THE USA INDEPENDENCE TUBE PRODUCT IS MANUFACTURED, TESTED, AND INSPECTED IN ACCORDANCE WITH ASTM STANDARDS ***** CURRENT STANDARDS:

..... A500/A500M-07

Stamp: PLEASA ANAHUAC Y CIAS. S.A. DE C.V. CONTROL DE CALIDAD. Includes fields for FECHA (18 Jun 2010) and FIRMA (E. RUIZ).

11May09 9:13

T E S T C E R T I F I C A T E

No: DCR 587339

Sold By:
INDEPENDENCE TUBE CORPORATION
6226 W. 74TH STREET
CHICAGO, IL 60638
Tel: 708-496-0380 Fax: 708-563-1950

P/O No CB01309
Rel
S/O No DCR 12543-002
B/L No DCR 9986-001 Shp 04May09
Inv No Inv

Sold To: (2950)
MIRACERO S.A. de C.V.
CALLE de la FUENTE 403
PISO 2 INT A COL MONCLOVA CENTRO
MONCLOVA, COAHUILA, MX 54030
MEXICO

Ship To: (1)
MIRACERO S.A. de C.V.
VIA 826 PUERTA 94
ZONA 11 NO. de CLIENTE 9092
TLALNEPANTLA, ESTADO deMX
MEXICO

Tel:

CERTIFICATE of ANALYSIS and TESTS

Cert. No: DCR 587339
04May09

..... A513-07

..... A252-98 (2002)

TEST CERTIFICATE DETAIL

Certificate Number: DCR 33026

Sold By:
INDEPENDENCE TUBE CORPORATION
 6226 W. 74th St.
 Chicago, IL 60638
 Tel: 708-496-0380
 Fax: 708-563-1950

Purchase Order No: CB01309
 Sales Order No: DCR 12543 - 2
 Bill of Lading No: DCR 9986 - 1
 Invoice No: DCR 20706 - 1

Shipped: 5/8/2009
 Invoiced: 5/8/2009

Sold To:
 2950 - **MIRACERO S.A. de C.V.**
 CALLE de la FUENTE 403
 PISO 2 INT A COL MONCLOVA CENTRO
 MONCLOVA, COAHUILA, MX 54030

Ship To:
 1 - **MIRACERO S.A. de C.V.**
 VIA 826 PUERTA 94
 ZONA 11 NO. de CLIENTE 9092
 TLALNEPANTLA, ESTADO deMX

Certificate No: DCR 33026
 Test Date: 5/8/2009

CERTIFICATE of ANALYSIS and TESTS

Customer Part No:

TUBING A500 GRADE B(C)
 12" SQ X 1/4" X 40"

Total Pieces Total Weight

Heat Number: X64715

Bundle Tag	Yield, Tensile Strength, Elongation, Measurements	Pieces	Weight
613518	YLD=52500/TEN=66400/ELG=48	4	6,309
613525	YLD=52500/TEN=66400/ELG=48	4	6,309
613526	YLD=52500/TEN=66400/ELG=48	4	6,309
613527	YLD=52500/TEN=66400/ELG=48	4	6,309
613528	YLD=52500/TEN=66400/ELG=48	4	6,309
613529	YLD=52500/TEN=66400/ELG=48	4	6,309
613530	YLD=52500/TEN=66400/ELG=48	4	6,309
613531	YLD=52500/TEN=66400/ELG=48	4	6,309


Heat Number: 7431H

Bundle Tag	Yield, Tensile Strength, Elongation, Measurements	Pieces	Weight
109562	YLD=56800/TEN=70100/ELG=36	2	3,154
109590	YLD=56800/TEN=70100/ELG=36	4	6,309
109609	YLD=56800/TEN=70100/ELG=36	4	6,309
109610	YLD=56800/TEN=70100/ELG=36	4	6,309
109612	YLD=56800/TEN=70100/ELG=36	2	3,154
109613	YLD=56800/TEN=70100/ELG=36	1	1,577
613513	YLD=56800/TEN=70100/ELG=36	1	1,577
613519	YLD=56800/TEN=70100/ELG=36	4	6,309
613520	YLD=56800/TEN=70100/ELG=36	4	6,309
613521	YLD=56800/TEN=70100/ELG=36	4	6,309
613524	YLD=56800/TEN=70100/ELG=36	4	6,309

Heat Number *** Chemical Analysis ***
 X64715 C=0.2 Mn=0.77 P=0.008 S=0.015 Si=0.01 Al=0.043 Cu=0.05
 7431H C=0.19 Mn=0.84 P=0.007 S=0.026 Si=0.02 Al=0.03 Cu=0.02

Certification:

I certify that the above results are a true and correct copy of records prepared and maintained by Independence Tube Corporation. Sworn this day, 5/8/2009.



Annette Gorz, Test Report Clerk

WE PROUDLY MANUFACTURE ALL OF OUR HSS IN THE USA.
 INDEPENDENCE TUBE PRODUCT IS MANUFACTURED, TESTED,
 AND INSPECTED IN ACCORDANCE WITH ASTM STANDARDS.

 CURRENT STANDARDS:
 A500/A500M-07
 A513-07
 A252-98 (2002)

TEST CERTIFICATE DETAIL

Certificate Number: DCR 33025

Sold By:
INDEPENDENCE TUBE CORPORATION
 6226 W. 74th St.
 Chicago, IL 60638
 Tel: 708-496-0380
 Fax: 708-563-1950

Purchase Order No: CB01309
 Sales Order No: DCR 12543 - 2
 Bill of Lading No: DCR 9985 - 4
 Invoice No: DCR 20602 - 2

Shipped: 5/7/2009
 Invoiced: 5/7/2009

Sold To:
 2950 - **MIRACERO S.A. de C.V.**
 CALLE de la FUENTE 403
 PISO 2 INT A COL MONCLOVA CENTRO
 MONCLOVA, COAHUILA, MX 54030

Ship To:
 1 - **MIRACERO S.A. de C.V.**
 VIA 826 PUERTA 94
 ZONA 11 NO. de CLIENTE 9092
 TLALNEPANTLA, ESTADO deMX

CERTIFICATE of ANALYSIS and TESTS

Certificate No: DCR 33025
 Test Date: 5/7/2009

Customer Part No:

TUBING A500 GRADE B(C)
 12" SQ X 1/4" X 40'

Total Pieces Total Weight

Heat Number: 7622H

Bundle Tag	Yield, Tensile Strength, Elongation, Measurements	Pieces	Weight
109601	YLD=55000/TEN=68200/ELG=41.2	4	6,309
109602	YLD=55000/TEN=68200/ELG=41.2	4	6,309
109603	YLD=55000/TEN=68200/ELG=41.2	4	6,309
109604	YLD=55000/TEN=68200/ELG=41.2	4	6,309
109605	YLD=55000/TEN=68200/ELG=41.2	4	6,309
109606	YLD=55000/TEN=68200/ELG=41.2	4	6,309
109607	YLD=55000/TEN=68200/ELG=41.2	4	6,309


Heat Number: 7431H

Bundle Tag	Yield, Tensile Strength, Elongation, Measurements	Pieces	Weight
109589	YLD=56800/TEN=70100/ELG=36	4	6,309
109593	YLD=56800/TEN=70100/ELG=36	4	6,309
109594	YLD=56800/TEN=70100/ELG=36	4	6,309
109595	YLD=56800/TEN=70100/ELG=36	4	6,309
109596	YLD=56800/TEN=70100/ELG=36	4	6,309
109597	YLD=56800/TEN=70100/ELG=36	4	6,309
109598	YLD=56800/TEN=70100/ELG=36	4	6,309
109599	YLD=56800/TEN=70100/ELG=36	4	6,309
109600	YLD=56800/TEN=70100/ELG=36	4	6,309
109608	YLD=56800/TEN=70100/ELG=36	4	6,309
613522	YLD=56800/TEN=70100/ELG=36	4	6,309
613523	YLD=56800/TEN=70100/ELG=36	4	6,309

Heat Number *** Chemical Analysis ***
 7622H C=0.19 Mn=0.85 P=0.008 S=0.004 Si=0.03 Al=0.033 Cu=0.02
 7431H C=0.19 Mn=0.84 P=0.007 S=0.026 Si=0.02 Al=0.03 Cu=0.02

Certification:

I certify that the above results are a true and correct copy of records prepared and maintained by Independence Tube Corporation. Sworn this day, 5/7/2009.



Annette Gorz, Test Report Clerk

WE PROUDLY MANUFACTURE ALL OF OUR HSS IN THE USA.
 INDEPENDENCE TUBE PRODUCT IS MANUFACTURED, TESTED,
 AND INSPECTED IN ACCORDANCE WITH ASTM STANDARDS.

CURRENT STANDARDS:

- A500/A500M-07
- A513-07
- A252-98 (2002)