

SHANDONG YUDING COLD-FORMED SECTION CO., LTD.
 LONGTAN EAST ST. HI-TECH DEVELOPMENT ZONE, LAIWU CITY, SHANDONG 271100, CHINA

MILL TEST CERTIFICATES

INVOICE NO.: 122051
 CONTRACT NO.: 122051
 APPLICANT:

TEST CERTIFICATE 122051
 DATE: AUG. 1, 2012
 L/C NO.: 5602159510

E-STEEL, INC.
 19401 S. VERMONT AVE
 SUITE I 106
 TORRANCE, CA 90502

DESCRIPTION OF GOODS:

ERW SQUARE AND RECTANGULAR TUBING ASTM A500 GRADE B

SIZE(INCHES) X WALL THICKNESS(INCHES) X LENGTH(Feet)	HEAT NUMBER	CHEMICAL COMPOSITION (%)					MECHANICAL PROPERTIES		
		C	Mn	Si	P	S	YIELD (N/mm ²)	TENSILE (N/mm ²)	ELONG. (%)
14"x14"x3/8x40'	H122-21060	0.17	0.65	0.17	0.017	0.004	385	505	27
12"x8"x3/8x40'	H122-21060	0.17	0.65	0.17	0.017	0.004	385	505	27
12"x4"x1/4x40'	H121-35107	0.17	0.65	0.20	0.020	0.008	405	525	27
12"x4"x3/16x40'	H121-35107	0.17	0.65	0.20	0.020	0.008	405	525	27
10"x10"x1/2x40'	H113-00298	0.17	0.61	0.15	0.018	0.006	397	520	26.5
14"x14"x3/8x40'	H113-00298	0.17	0.61	0.15	0.018	0.006	397	520	26.5
6"x6"x3/8x40'	H121-02781	0.18	0.65	0.18	0.021	0.011	415	518	27.5
TOTAL:									

ORIGIN CHINA

PAGE:1-1