MAQUILACERO

Av. Adolfo López Mateos 1220, Col. Margarita Rdz Salazar, San Nicolas de Los Garza, N.L.
Codigo Postal / Postal Code: 66479 Telefono / Phone number: +52(81)8158-0300 www.maquilacero.com

CERTIFICADO DE CALIDAD - MILL TEST CERTIFICATE
Fecha de emision /(Date of invoice) 11/07/2019

Codigo de cliente /(Customer ID) Cliente /(Customer) MAQUILACERO,SA,DE,C.V.

Factura / (Invoice Num.) 4761

Direccion / (Address) AV.ADOLFO LOPEZ MATEOS NO 1220 ,MARGARITAS RODRIGUEZ SALAZAR CIUDAD SAN NICOLAS DE LOS GARZA NUEVO LEON ,MEXICO

Pedido /

Destinatario / (Consignated to) SEPTIMA AV 140 PARQUE INDUSTRIAL MONTERREY CIUDAD APODACA NUEVO LEON MEXICO

Orden de compra

Part (Item)	Descripcion / (Description)	Cantidad / Quantity	Unidad	No. Lote (Lot Number)	Colada (heat)	ASTM	Composicion Quimica (Chemical Composition)				Prueba de Tension			
							C	Mn	P	S	Cedencia(ksi)	Resistencia a la Tencion (ksi)	% Elong.	Dureza(hrb)
PRN600600250122N	PTR6x6C-1/4,12.20 MTS	36.38	TON	-	1942459	A-500 GRADO B	0.069	0.571	0.009	0.002	53	66	25	75
			TON	-	1842459	A-500 GRADO B	0.095	0.47	0.01	0.003	50	64	27	73

Certificamos que el material descrito satisface las especificaciones requeridas. La composicion quimica son transcripcion de los certificados del Proveedor de acero.
We certify that the above described material satisfies the required specifications. The chemical composition is transcription from the mill test certificate. of the steel supplier.
NOTE: NINGUN PRODUCTO HA SIDO PROBADO HIDROSTATICAMENTE. NONE OF THIS PRODUCTS HAVE BEEN HYDROSTATICALLY TESTED. NO WELD REPAIR WAS MADE IN ALL THIS ITEMS.

Quality Lab.