

SIDERTUL, S.A. DE C.V.
 CALLE 3 S/N, COL. INDEPENDENCIA
 TULTITLAN, EDO., DE MEXICO, C.P. 54900

PRODUCTO

Varilla

CLIENTE PLESA ANAHUAC Y CIAS SA DE CV	GRADO GR 42
---	-----------------------

FACTURA 91614386	Nº PEDIDO DEL CLIENTE 18206	PEDIDO DEL CLIENTE 922130/000010	ESPECIFICACIÓN NMX-C-407-ONNCCE-2001
----------------------------	---------------------------------------	--	--

CALIBRE	LOTE	PESO (Kg)	C %	Mn %	S %	P %	Dobl.	E.F. MPa	R.T. MPa	Alarg %						
1	1022103703	8,120	0.4200	0.95	0.039	0.015	OK	428	676	17.00						
1	1022105702	2,040	0.4000	0.99	0.033	0.022	OK	439	728	17.00						

PROPIEDADES MECÁNICAS Alarg - Alargamiento Dobl. - Ensayos de Doblado E.F. - Esfuerzo de Fluencia Mpa R.T. - Resistencia a la Tensión Mpa	OBSERVACIONES El presente certificado garantiza que el material cumple los requisitos definidos en las normas NMX-C-407-ONNCCE-2001 y NMX-B-506-CANACERO-2011.	RESPONSABLE DE CALIDAD
		TULTITLAN, 29.04.2014 SALVADOR ISAAC MEDINA RABADAN