

SIDERTUL, S.A. DE C.V.
 CALLE 3 S/N, COL. INDEPENDENCIA
 TULTITLAN, EDO., DE MEXICO, C.P. 54900

No. CERTIFICADO
0000023592

CLIENTE PLESA ANAHUAC Y CIAS SA DE CV	GRADO GR 42	PRODUCTO Varilla
---	-----------------------	----------------------------

FACTURA 91626580	Nº PEDIDO DEL CLIENTE 18229	PEDIDO DEL CLIENTE 928903/000010	ESPECIFICACIÓN NMX-C-407-ONNCCE-2001
----------------------------	---------------------------------------	--	--

CALIBRE	LOTE	PESO (Kg)	C %	Mn %	S %	P %	Dobl.	E.F. MPa	R.T. MPa	Alarg %					
3/8	1022123302	4,090	0.5000	0.97	0.037	0.019	OK	503	777	10.00					
3/8	1022131902	6,208	0.3800	0.92	0.036	0.016	OK	443	668	16.00					

PROPIEDADES MECÁNICAS Alarg - Alargamiento Dobl. - Ensayos de Doblado E.F. - Esfuerzo de Fluencia Mpa R.T. - Resistencia a la Tensión Mpa	OBSERVACIONES El presente certificado garantiza que el material cumple los requisitos definidos en las normas NMX-C-407-ONNCCE-2001 y NMX-B-506-CANACERO-2011.	RESPONSABLE DE CALIDAD
		TULTITLAN, 03.05.2014 SALVADOR ISAAC MEDINA RABADAN