


SIDERTUL, S.A. DE C.V.
 CALLE 3 S/N, COL. INDEPENDENCIA
 TULTITLAN, EDO., DE MEXICO, C.P. 54900

 No. CERTIFICADO
0000076084

CLIENTE DISEÑO ARTISTICO Y ENSAMBLE SA DE		GRADO GR 42	PRODUCTO Varilla
FACTURA 99094134	N° PEDIDO DEL CLIENTE OC- O-ACE66	PEDIDO DEL CLIENTE 5412572/000010	ESPECIFICACIÓN NMX-B-506-CANACERO-2011

CALIBRE	LOTE	PESO (Kg)	Largo m	C	Mn	S	P	Dobl.	E.F. MPa	R.T. MPa	Alarg						
1/2	1024380603	2,058	12.00	0.4000	0.64	0.023	0.021	OK	561	702	17.00						
1/2	1024380803	8,102	12.00	0.3900	0.65	0.047	0.016	OK	553	695	15.00						
1/2	1024381803	6,176	12.00	0.3900	0.59	0.042	0.009	OK	547	696	16.50						

PROPIEDADES MECÁNICAS Alarg - Alargamiento Dobl. - Ensayos de Doblado E.F. - Esfuerzo de Fluencia Mpa R.T. - Resistencia a la Tensión Mpa	OBSERVACIONES ASTM A615/A615 M-06a. El presente certificado garantiza que el material cumple los requisitos definidos en las normas NMX-C-407-ONNCC-2001, NMX-B-506-CANACERO-2011 y	RESPONSABLE DE CALIDAD
		TULTITLAN, 27.07.2017  SALVADOR ISAAC MEDINA RABADAN