


SIDERTUL, S.A. DE C.V.
 CALLE 3 S/N, COL. INDEPENDENCIA
 TULTITLAN, EDO., DE MEXICO, C.P. 54900

No. CERTIFICADO
0000022154

CLIENTE PLESA ANAHUAC Y CIAS SA DE CV	GRADO GR 42	PRODUCTO Varilla
---	-----------------------	----------------------------

FACTURA 91504105	Nº PEDIDO DEL CLIENTE 17933	PEDIDO DEL CLIENTE 843162/000010	ESPECIFICACIÓN NMX-C-407-ONNCCE-2001
----------------------------	---------------------------------------	--	--

CALIBRE	LOTE	PESO (Kg)	C %	Mn %	S %	P %	Dobl.	E.F. MPa	R.T. MPa	Alarg %						
1/2	1022080702	14,406	0.4300	0.85	0.044	0.020	OK	441	684	14.50						
1/2	1022080902	16,404	0.4200	0.85	0.041	0.023	OK	445	685	15.50						

PROPIEDADES MECÁNICAS Alarg - Alargamiento Dobl. - Ensayos de Doblado E.F. - Esfuerzo de Fluencia Mpa R.T. - Resistencia a la Tensión Mpa	OBSERVACIONES El presente certificado garantiza que el material cumple los requisitos definidos en las normas NMX-C-407-ONNCCE-2001 y NMX-B-506-CANACERO-2011.	RESPONSABLE DE CALIDAD
		TULTITLAN, 25.03.2014  SALVADOR ISAAC MEDINA RABADAN