

SIDERTUL, S.A. DE C.V.
 CALLE 3 S/N, COL. INDEPENDENCIA
 TULTITLAN, EDO., DE MEXICO, C.P. 54900

No. CERTIFICADO
000002318


PRODUCTO

Varilla

| | |
|---|-----------------------|
| CLIENTE PLESA ANAHUAC Y CIAS SA DE CV | GRADO GR 42 |
|---|-----------------------|

| | | | |
|----------------------------|---------------------------------------|--|--|
| FACTURA 90293062 | Nº PEDIDO DEL CLIENTE 14136 | PEDIDO DEL CLIENTE 158573/000020 | ESPECIFICACIÓN NMX-C-407-ONNCCE-2001 |
|----------------------------|---------------------------------------|--|--|

| CALIBRE | LOTE | PESO (Kg) | C % | Mn % | S % | P % | Dobl. | E.F. MPa | R.T. MPa | Alarg % | | | | | | |
|---------|------------|--------------|--------|---------|--------|--------|-------|-------------|-------------|------------|--|--|--|--|--|--|
| 5/8 | 1021037802 | 22,200 | 0.3900 | 0.94 | 0.034 | 0.009 | OK | 450 | 714 | 15.50 | | | | | | |
| 5/8 | 1021037902 | 14,128 | 0.3900 | 0.94 | 0.034 | 0.009 | OK | 452 | 708 | 18.00 | | | | | | |

| | | |
|--|--|---|
| PROPIEDADES MECÁNICAS Alarg - Alargamiento Dobl. - Ensayos de Doblado E.F. - Esfuerzo de Fluencia Mpa R.T. - Resistencia a la Tensión Mpa | OBSERVACIONES El presente certificado garantiza que el material cumple los requisitos definidos en las normas NMX-C-407-ONNCCE-2001 y NMX-B-506-CANACERO-2011. | RESPONSABLE DE CALIDAD |
| | | TULTITLAN, 03.10.2012.  SALVADOR ISAAC MEDINA RABADAN |