


CALLE 3 Col. Independencia Tultitlan S/N, Independencia  
Tutitlan, México. C.P - 54900 Tel/Fax: 58940899

CLIENTE <b>PLESA ANAHUAC Y CIAS S A DE C V</b>	GRADO <b>GR 42</b>	PRODUCTO <b>Varilla</b>
---	-----------------------	----------------------------

FACTURA <b>90004665</b>	N° PEDIDO DEL CLIENTE <b>10455</b>	PEDIDO DEL CLIENTE <b>3001</b>	ESPECIFICACIÓN <b>NMX-C-407-ONNCCE-2001</b>
----------------------------	---------------------------------------	-----------------------------------	--

CALIBRE	LOTE	PESO (Kg)	C %	Mn %	P %	S %	Alarg %	Dobr	P.C. MPa	U.R. MPa						
3/4	1020109702	22,438.000	0.3900	1.22	0.019	0.034	14.00	OK	465	729						
3/4	1020109802	8,156.000	0.4000	1.14	0.018	0.031	14.00	OK	470	733						

<b>PROPIEDADES MECÁNICAS</b> Alarg - Alongamento Dobr - Ensayos de Doblado P.C. - Limite de Escoamento Mpa U.R. - Limite de Resistência MPA	<b>OBSERVACIONES</b>  	<b>RESPONSABLE DE CALIDAD</b>  TUTITLAN, 01.06.2011    _____ ING. MANUEL RODILES DUARTE
---	------------------------------	---