



CERTIFICADO DE CALIDAD/QUALITY CERTIFICATE

EN 10 204 3.1 B

<b>Factura / Invoice:</b>	<b>Cantidad / Quantity:</b>	<b>Certificado / Certificate:</b>	<b>Fecha / Date:</b>
100194	50.00	EE100194/16	23/Abr/04
<b>Descripción / Description:</b>			
411-T 3/4" S.E. NPT			
<b>Cliente / Customer:</b>			
7 PLESA ANAHUAC Y CIAS., S.A. DE C.V.			


**Numeros de Rastreabilidad / Traceability Number:**


**03K12279 A 03K12288,03K11929 A 03K11938,03K11879 A 03K11888  
03K12329 A 03K12338,03K12379 A 03K12388**


**ORIGINAL**

Válvulas Worcester de México, S.A. de C.V., certifica que el material indicado cumple con nuestras especificaciones como se describe en nuestros catálogos, hojas de especificación, dibujos y en otra literatura. Los productos, partes, materiales indicados aquí han sido comprados, fabricados, inspeccionados y probados de acuerdo con estas especificaciones, a nuestro sistema de calidad ISO 9001, y ASME/ANSI B16.34-1998 inciso (7).

Válvulas Worcester de México, S.A. de C.V., hereby certifies that the material supplied is in accordance with our specifications as describe in our catalog, specification sheets, drawings, and other literature. The products, parts and materials identified herein have been purchased, manufactured, inspected and tested in accordance with these specifications, our ISO 9001 quality assurance program, and ASME/ANSI B16.34-1998 part (7).

Elaboro / Elaborated by:   
 Jose Luis Pérez C.  
 Metrologista

Aprobo / Aprobed by:   
 Ing. Saturnino Padilla Becerra.  
 Gerente de Aseguramiento de Calidad  
 Quality Ass. Manager.



# VALVULAS WORCESTER DE MEXICO, S.A. DE C.V. RHINO VALVES WORLDWIDE



## CERTIFICADO DE CALIDAD / QUALITY CERTIFICATE

CERTIFICADO / CERTIFICATE:

EE100194/16

No.	COMPONENTES	MATERIAL
1	CUERPO / BODY	ASTM B124 C37700
2	TAPA / PIPE END	ASTM B124 C37701
3	VASTAGO / STEM	AISI 316
4	ESFERA / SPHERE	UNI EN 12164CW614N

No.	C%	Mn%	Si%	P%	S%	Cr%	Mo%	Ni%	Cu%	V%	Fe%	Al%	Nb%	Zn%	Pb%	Sn%	PROPIEDADES MECANICAS / MECHANICAL PROPERTIES						
																	RESISTENCIA A LA TENSION TENSILE STRENGTH	LIMITE DE CEDENCIA YIELD STRENGTH	% ELONGACION % ELONGATION	REDUCCION DE AREA REDUCTION AREA	DUREZA HARDNESS		
1	X	0.002	0.003	X	X	0.002	X	X	58.680	X	0.234	0.001	X	39.050	2.010	0.016	X	X	X	60 RB			
2	X	0.004	0.025	X	X	X	X	X	58.210	X	0.259	0.093	X	39.350	2.040	0.025	X	X	X	60RB			
3	0.040	1.540	0.240	0.025	0.021	16.830	2.030	10.140	X	X	X	X	X	X	X	X	X	88466 Psi	32376 Psi	45	X	X	130 HB
4	X	X	X	X	X	X	X	0.300	59.000	X	0.300	0.050	X	X	X	0.300	X	X	X	X	X		

**ORIGINAL**

TIPO DE PRUEBA TYPE OF TEST	PSI	RESULTADO RESULT
PRUEBA HIDRAULICA DEL CUERPO HYDRAULIC TEST ON BODY	900	SIN FUGA "OK" NO LEAKAGE FOUND
PRUEBA HIDRAULICA EN ASIENITOS HYDRAULIC TEST ON SEATS	700	SIN FUGA "OK" NO LEAKAGE FOUND
PRUEBA NEUMATICA EN ASIENITOS NEUMATIC TEST ON SEATS	50-80	SIN FUGA "OK" NO LEAKAGE FOUND