



VALVULAS WORCESTER DE MEXICO, S.A. DE C.V.

RHINO VALVES WORLDWIDE



CERTIFICADO DE CALIDAD/QUALITY CERTIFICATE

EN 10 204 3.1 B

Factura / Invoice:	Cantidad / Quantity:	Certificado / Certificate:	Fecha / Date:
107697	20.00	EE107697/6	28/Abr/05
Descripción / Description:			
444-T 2" 150 #			
Cliente / Customer:			
7 PLESA ANAHUAC Y CIAS., S.A. DE C.V.			

Numeros de Rastreabilidad / Traceability Number:

05A05006,05A04937,05A04962,05A04982,05A04970,05A04963,05A05012
05A04981,05A04931,05A04972,05A05014,05A04978,05A04965,05A04927
05A04933,05A04932,05A04994,05A04966,05A04930,05A05015

ORIGINAL



Válvulas Worcester de México, S.A. de C.V., certifica que el material indicado cumple con nuestras especificaciones como se describe en nuestros catálogos, hojas de especificación, dibujos y en otra literatura. Los productos, partes, materiales indicados aquí han sido comprados, fabricados, inspeccionados y probados de acuerdo con estas especificaciones, a nuestro sistema de calidad ISO 9001, NACE MR-01-75 y ASME/ANSI B16.34-1998 inciso (7).

Válvulas Worcester de México, S.A. de C.V., hereby certifies that the material supplied is in accordance with our specifications as describe in our catalog, specification sheets, drawings, and other literature. The products, parts and materials identified herein have been purchased, manufactured, inspected and tested in accordance with these specifications, our ISO 9001 quality assurance program, NACE MR-01-75 and ASME/ANSI B16.34-1998 part (7).

Elaboro / Elaborated by:

Jose Luis Perez C.
Metrologista


Aprobo / Aproved by:

Ing. Saturno Padilla Becerra.
Gerente de Aseguramiento de Calidad
Quality Ass. Manager.

Maíz No. 263, Colonia Valle del Sur, Delegación Iztapalapa, México D.F. C.P. 09819

Teléfonos: 56-70-51-55 (8 líneas) 56-70-66-24 55-82-91-03 5582-30

Fax: 56-70-67-41 56-70-35-13 e-mail: calidadw@worcester.com.mx



**VALVULAS WORCESTER DE MEXICO, S.A. DE C.V.
RHINO VALVES WORLDWIDE**



CERTIFICADO DE CALIDAD / QUALITY CERTIFICATE

CERTIFICADO / CERTIFICATE: EE107697/6

No.	COMPONENTES COMPONENTS	MATERIAL MATERIAL
1	CUERPO / BODY	ASTM A216 WCB
2	TAPA / PIPE END	ASTM A216 WCB
3	VASTAGO / STEM	AISI 12L14
4	ESFERA / SPHERE	ASTM A351 CF8M

ANALISIS QUIMICO / CHEMICAL ANALYSIS											PROPIEDADES MECANICAS / MECHANICAL PROPERTIES										
No.	C%	Mn%	Si%	P%	S%	Cr%	Mo%	Ni%	Cu%	V%	Fe%	Al%	N%	Zn%	Pb%	Sn%	RESISTENCIA A LA TENSION TENSILE STRENGTH	LIMITE DE CEDENCIA YIELD STRENGTH	% ELONGACION % ELONGATION	REDUCCION DE AREA REDUCCION DE AREA	DUREZA HARDNESS
1	0.220	0.930	0.360	0.016	0.014	0.087	0.005	0.028	0.009	0.001	X	X	X	X	X	X	515 Mpa	305 Mpa	30	51	165 HB
2	0.230	0.930	0.400	0.020	0.017	0.236	0.024	0.079	0.032	0.002	X	X	X	X	X	X	530 Mpa	305 Mpa	26	50	170 HB
3	0.080	1.150	0.060	0.058	0.280	0.060	0.005	0.040	0.070	X	X	X	X	X	0.280	X	X	X	X	X	172 BHN
4	0.076	1.160	1.280	0.038	0.015	19.800	2.200	9.760	X	X	X	X	X	X	X	X	75383 PSI	42341 PSI	49	X	169 HB

ORIGINAL

TIPO DE PRUEBA TYPE OF TEST	PSI	RESULTADO RESULT
PRUEBA HIDRAULICA DEL CUERPO HYDRAULIC TEST ON BODY	450	SIN FUGA "OK" NO LEAKAGE FOUND
PRUEBA HIDRAULICA EN ASIENTOS HYDRAULIC TEST ON SEATS	350	SIN FUGA "OK" NO LEAKAGE FOUND
PRUEBA NEUMATICA EN ASIENTOS NEUMATIC TEST ON SEATS	50-80	SIN FUGA "OK" NO LEAKAGE FOUND